

Light efficiency:

98 Lumen/Watt

Light quality:

CRI: 81,1

Color temperature:


6000 K

Output: 3908 lm

Peak: 1316 cd

Power: 39,7 W

PF: 0,97



Beam angle

114,4°

Tracking number: [VT241003-004601](#)

Product name:

277663-6000K

Item number:

277663-6000K

Date and time:

3-10-2024 13:05:12


Description:

**BACK-LIT LED PANEEL | LEDA |
120X30CM | 40W**






CIE 1931
x: 0,322
y: 0,332

Spectra




Power






TM-30: 83,4



CRI: 81,1 (R1-R8)



CRI R values, only R1-R8 are used to calculate final CRI value

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
78,4	84,1	89,7	82,4	80,1	79,9	86,7	67,6	-1,8	63,9	82,4	62,0	79,5	94,6	71,0


TM30 C values, 16 binned values out of total of 99 C values

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
75,6	84,3	77,6	84,1	87,3	91,5	94,0	86,3	88,2	79,7	75,3	87,8	87,7	82,9	74,0	83,0

CQS Q values

Q1	Q2	Q3	Q4	Q5	Q6	Q7	Q8	Q9	Q10	Q11	Q12	Q13	Q14	Q15
83,2	97,1	78,4	77,1	82,7	83,7	85,4	90,1	96,5	85,3	83,0	82,3	81,9	68,0	73,8

CQS: 81,7



Color parameters

Color temperature	Color rendering index	Red component	Color fidelity	Color gamut	Color quality scale	Color coordinate cie 1931	Color coordinate cie 1931	Color coordinate	Color coordinate	Color deviation from black body
CCT	CRI	CRI R9	TM30 Rf	TM30 Rg	CQS	x	y	u	v	Δuv
6000 K	81,1	-1,8	83,4	96,3	81,7	0,322	0,332	0,203	0,314	0,0043







Rf 83,4


Fidelity index Rf

Rg 96,3

Gamut index Rg

Hue Bin	R _f	Shifts (%)	
		Chroma	Hue
1	76	-13%	-3%
2	84	-9%	5%
3	78	-5%	12%
4	84	1%	10%
5	87	4%	5%
6	92	4%	-1%
7	94	0%	-4%
8	86	-7%	-5%
9	88	-10%	3%
10	80	-7%	10%
11	75	0%	15%
12	88	4%	7%
13	88	9%	-3%
14	83	6%	-8%
15	74	4%	-23%
16	83	-5%	-9%




Beam intensities from 1-20m

1m	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m	12m	13m	14m	15m	16m	17m	18m	19m	20m
3,3ft	6,6ft	9,8ft	13,1ft	16,4ft	19,7ft	23ft	26,2ft	29,5ft	32,8ft	36,1ft	39,4ft	42,7ft	45,9ft	49,2ft	52,5ft	55,8ft	59,1ft	62,3ft	65,6ft
1316lx	329lx	146lx	82lx	53lx	37lx	27lx	21lx	16lx	13lx	11lx	9lx	8lx	7lx	6lx	5lx	5lx	4lx	4lx	3lx
122,2fcd	30,6fcd	13,6fcd	7,6fcd	4,9fcd	3,4fcd	2,5fcd	1,9fcd	1,5fcd	1,2fcd	1fcd	0,8fcd	0,7fcd	0,6fcd	0,5fcd	0,5fcd	0,4fcd	0,4fcd	0,3fcd	0,3fcd

Intensities in 0° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
1316	1311	1295	1268	1229	1182	1123	1056	979	895	803	703	599	490	380	272	170	79	18	5
100%	100%	98%	96%	93%	90%	85%	80%	74%	68%	61%	53%	46%	37%	29%	21%	13%	6%	1%	0%

Intensities in 90° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
1316	1311	1295	1268	1229	1182	1123	1056	979	895	803	703	599	490	380	272	170	79	18	5
100%	100%	98%	96%	93%	90%	85%	80%	74%	68%	61%	53%	46%	37%	29%	21%	13%	6%	1%	0%


Intensities in 180° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
1316	1311	1295	1268	1229	1182	1123	1056	979	895	803	703	599	490	380	272	170	79	18	5
100%	100%	98%	96%	93%	90%	85%	80%	74%	68%	61%	53%	46%	37%	29%	21%	13%	6%	1%	0%

Intensities in 270° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
1316	1311	1295	1268	1229	1182	1123	1056	979	895	803	703	599	490	380	272	170	79	18	5
100%	100%	98%	96%	93%	90%	85%	80%	74%	68%	61%	53%	46%	37%	29%	21%	13%	6%	1%	0%

Beam angle 50%	Field angle 10%	Cutoff angle 2,5%	Intensity ratio in 120° cone	Intensity ratio in 90° cone
114,4°	164,2°	177,4°	76,9%	52,0%


iso-candela diagram


10%	132 cd
20%	263 cd
30%	395 cd
40%	526 cd
50%	658 cd
60%	789 cd
70%	921 cd
80%	1052 cd
90%	1184 cd

Conditions:

Number of c-planes: 12

Candela at center: 1316 cd

iso-lux diagram


3%	0,395 lx
5%	0,658 lx
10%	1,32 lx
30%	3,95 lx
50%	6,58 lx

Conditions:

Number of c-planes: 12

Lux at center: 13,2 lx

*Lux distribution on a surface
when lamp is mounted at 10
meters from the surface.*

Glare evaluation according to UGR


p Ceiling		70	70	50	50	30	70	70	50	50	30
p Walls		50	30	50	30	30	50	30	50	30	30
p Floor		20	20	20	20	20	20	20	20	20	20
Room size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	17,5	18,7	17,8	19,1	19,3	17,4	18,7	17,7	19,0	19,2
	3H	19,0	20,3	19,5	20,6	20,8	18,9	20,2	19,3	20,5	20,7
	4H	19,7	20,9	20,1	21,2	21,5	19,5	20,7	20,0	21,0	21,3
	6H	20,3	21,3	20,6	21,6	22,0	20,1	21,1	20,4	21,4	21,8
	8H	20,4	21,5	20,8	21,8	22,2	20,2	21,3	20,6	21,6	22,0
	12H	20,5	21,6	20,9	21,9	22,4	20,3	21,3	20,7	21,7	22,1
4H	2H	18,1	19,3	18,5	19,6	19,9	18,0	19,3	18,5	19,5	19,8
	3H	19,9	21,0	20,3	21,3	21,8	19,8	20,8	20,2	21,2	21,7
	4H	20,7	21,6	21,1	22,0	22,6	20,5	21,4	21,0	21,9	22,4
	6H	21,3	22,2	21,8	22,5	22,9	21,1	22,0	21,6	22,4	22,7
	8H	21,5	22,3	22,0	22,7	23,1	21,3	22,1	21,8	22,5	22,9
	12H	21,7	22,3	22,2	22,8	23,3	21,4	22,1	21,9	22,5	23,0
8H	4H	20,9	21,7	21,5	22,1	22,5	20,8	21,6	21,3	22,0	22,4
	6H	21,7	22,4	22,2	22,8	23,4	21,6	22,2	22,1	22,7	23,2
	8H	22,1	22,6	22,6	23,1	23,8	21,9	22,4	22,4	22,9	23,6
	12H	22,3	22,8	22,9	23,3	23,9	22,1	22,5	22,7	23,1	23,7
12H	4H	21,0	21,6	21,5	22,1	22,6	20,8	21,5	21,3	21,9	22,4
	6H	21,8	22,4	22,3	22,9	23,5	21,7	22,2	22,2	22,7	23,4
	8H	22,2	22,6	22,8	23,1	23,8	22,0	22,4	22,6	22,9	23,6
Variation of the observer position for the luminaire distance S											
S = 1.0H		0,1 / -0,1					0,1 / -0,1				
S = 1.5H		0,1 / -0,2					0,1 / -0,2				
S = 2.0H		0,4 / -0,4					0,4 / -0,5				
CIE 117-1995. Corrected glare indices referring to 3908 lm total luminous flux											

Coefficients of Utilization

Ceiling reflectance	80				70				50			30			10			0
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR	(RCR: Room Cavity Ratio) Room Values are expressed as percentage of Lumens delivered to the task surface																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
1	108	103	99	95	105	101	97	93	96	93	90	92	90	87	89	86	84	82
2	98	90	83	77	95	88	81	76	84	79	74	81	76	72	77	74	70	68
3	89	79	70	64	87	77	69	63	74	67	62	71	65	61	68	63	59	57
4	82	69	61	54	79	68	60	53	65	58	52	63	57	52	61	55	51	49
5	75	62	53	46	73	61	52	46	59	51	45	56	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	40	51	44	39	49	43	39	37
7	64	51	42	35	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	37	32	58	45	37	31	44	36	31	43	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23

LAMPS (number of lamps)

Luminaire budgetary diagram




Zonal Lumen Summary


0°-10°	10°-20°	20°-30°	30°-40°	40°-50°	50°-60°	60°-70°	70°-80°	80°-90°
{LUM0-10}	358 lm	544 lm	660 lm	690 lm	628 lm	485 lm	288 lm	92,9 lm
90°-100°	100°-110°	110°-120°	120°-130°	130°-140°	140°-150°	150°-160°	160°-170°	170°-180°
7,10 lm	4,87 lm	5,34 lm	5,26 lm	4,81 lm	4,11 lm	3,24 lm	2,07 lm	0,730 lm

LCS table

BUG rating:	B2 U2 G1	
Forward light	Lumens	Lumens %
Low(0-30):	513,1	13,1%
Medium(30-60):	988,7	25,3%
High(60-80):	386,6	9,9%
Very high(80-90):	46,6	1,2%
Back light		
Low(0-30):	513,1	13,1%
Medium(30-60):	988,7	25,3%
High(60-80):	386,6	9,9%
Very high(80-90):	46,6	1,2%
Uplight		
Low(90-100):	7,5	0,2%
High(100-180):	30,4	0,8%

LCS graph



Warmup curve

Warmup result

Warmup time:	Lamp stabilized in 15 min 1 sec
Warmup variation	-0,9%

Warmup conditions

Stable period:	15 min
Stable change max:	2,0%
Minimum time:	15 min



Color temperature change

CCT start	CCT change	CCT end
5985 K	+15 K	6000 K

Output change

Output start	Output change	Output end
3943 lm	-35 lm	3908 lm

Flicker curve (complete sampled flicker signal)

Flicker frame (frame of one flicker period)

Flicker FFT (frequency scope of flicker curve)

Flicker results:

Flicker frequency:		102,04 Hz	
Flicker index:	0	JA8/10 40Hz	0,02 %
Flicker percentage:	0,27 %	JA8/10 90Hz	0,04 %
SVM: (Visual flicker)	0,01	JA8/10 200Hz	0,21 %
PstLM	0,02	JA8/10 400Hz	0,22 %
Mp	0,01	JA8/10 1000Hz	0,25 %

Flicker conditions:

Sample rate:	20000 samples/second
--------------	----------------------